

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING NO. 3550-0006:105 Page 1 of 1

CATEGORY: Fire-Rated Door Closers/holders

LISTEE: Sargent Manufacturing, 100 Sargent Drive, New Haven CT 06536
Contact: *Dan Picard (203) 498-5634 Fax (203) 498-5600

DESIGN: Models 2400 and 2500 series door closers/holders. Models may have the following prefixes: 9- (companion unit), 12- (with smoke detector), or no prefix (stand alone unit). Refer to listee's data sheet (Form No. 2425/992) for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, electrical rating and UL label.

APPROVAL: Listed as door closers/holders for use on fire-rated doors. For model with an integral smoke detector, Model System Sensor DOR2400 (CSFM Listing No: 7272-1209:153) or *SSD Photo (CSFM Listing No: 7270-1209:162) photoelectric smoke detectors must be used.

*Rev. 06-08-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 8, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager